

Requirement	Construction Contractor Daily Use Checklist for FIRE PROTECTION	YES	NO	NA
1926.150	Is there a fire protection program for all phases of construction or demolition work?			
1926.150	Is access to fire fighting equipment maintained at all times?			
1926.150	Is fire fighting equipment conspicuously located?			
1926.150	Is fire fighting equipment periodically inspected and if found defective immediately replaced?			
1926.150	Is a fire extinguisher, rated not less than 2A, provided for each 3,000 square feet of the protected building area, or major fraction thereof?			
1926.150	Is the travel distance from any point of the protected area to the nearest fire extinguisher less than 100 feet?			
1926.150	Is there at least one fire extinguisher, rated not less than 2A provided on each floor?			
1926.150	Is there at least one fire extinguisher located adjacent to stairways on each floor of a multistory building?			
1926.150	Is a fire extinguisher, rated not less than 10B, provided within 50 feet of wherever more than 5 gallons of flammable or combustible liquids or 5 pounds of flammable is gas being used on the jobsite?			
1926.150	Are carbon tetrachloride or other toxic vaporizing liquid fire extinguishers prohibited?			
1926.150	Are portable fire extinguishers inspected periodically and maintained in accordance with maintenance and use of portable fire extinguishers NFPA No. 10A?			
1926.150	Is there an alarm system whereby employees and the local fire department can be alerted for emergencies?			
1926.150	Are reporting instructions for fire conspicuously posted at phones or at employee entrances?			
1926.151	Is smoking prohibited at or in the vicinity of operations which constitute a fire hazard and is "No Smoking or Open Flame" conspicuously posted?			
1926.151	Are portable fire extinguishers, suitable for the fire hazards involved provided at convenient conspicuously accessible locations in the yard area?			
1926.151	Is indoor storage placed where it will not obstruct or adversely affect the means of exit?			
Supervisor Signature: _____ PO#/FWR# _____ Date: _____ Company: _____ Comments: _____				

