

Requirement	Construction Contractor Daily Use Checklist for ROOFING (Hot Tar, Torch Applied)	YES	NO	NA
NFPA 241	Has a hot work permit been obtained from the MSFC S&MA Office? (MSFC form 1155) S&MA Office 544-0046			
NFPA 241	Are tar kettles located at least 25 feet from any building of combustible material?			
NFPA 241	Is the tar kettle attended at all times during use?			
NFPA 241	Is the kettle provided with a lid and thermometer?			
NFPA 241	Are there two 20 BC fire extinguishers provided and maintained within 25 feet of the kettle?			
NFPA 241	Is the torch (torch applied system) being used in an area where flame impingement is in total view?			
NFPA 241	Is combustible insulation and other combustible materials covered with a base ply?			
NFPA 241	Is a fire watch maintained for a minimum of 1 hour after torches have been extinguished?			
Supervisor Signature: _____ PO#/FWR# _____ Date: _____ Company: _____ Comments: _____				