

Requirement	Construction Contractor Daily Use Checklist for TOOLS AND EQUIPMENT	YES	NO	NA
1926.300	Have all tools been inspected to be in a safe condition?			
1926.300	Are personnel provided with personal protective equipment to protect against falling, flying, abrasive objects, or generated dusts?			
1926.300	Are openings of guard covers over fan rotating blades no larger than ½ inch?			
	Hand Tools			
1926.301	Are impact tools (pins, wedges, chisels) free of mushroom heads?			
1926.301	Are handles free of splinters and tight on the tool?			
	Powder-Actuated Tools			
1926.302	Are personnel trained in the operation of the particular tool to be used?			
	Power Tools			
1926.404	Are ground-fault circuit interrupters provided on all temporary electrical 15 and 20-ampere circuits?			
1926.302	Are power tools double insulated or grounded?			
1926.300	Are reciprocating, rotating, moving parts and point of operation guarded where the operation exposes employees to injury?			
1926.304	Are portable circular saws equipped with guards above and below the base shoe?			
1926.405	Are flexible cords used in continuous lengths without splice or tap and connected to devices and fittings so that strain relief is provided which will prevent pull from being directly transmitted to joints or terminal screws.			
1926.300	Have the switches of power tools been tested for proper operation?			
	Pneumatic Power tools			
1926.302(b)	Are the tools secured to the hose or whip by a positive means to prevent the tool from becoming disconnected?			
1926.302(b)	Are safety clips or retainers installed to prevent attachments from being expelled?			
1926.302(b)	Are tools which operate at 100 psi and equipped with automatic fastener feed provided with a safety device to prevent the tool from ejecting the fasteners.			
1926.302(b)	Are cleaning operations using compressed air limited to 30 psi?			
1926.300	Has the power switch been tested for proper operation?			
Supervisor Signature: _____ PO#/FWR# _____ Date: _____ Company: _____ Comments: _____				